

Dated: 17.04.2018

REPLY TO PRE-BID QUERIES

BIDDING DOCUMENT NO. : MEC/23TS/01/51/D2/T02/SU/0001 dated 31.03.2018

SUBJECT OF BIDDING DOCUMENT : SUPPLY OF GAS REGULATORS

Sr. No.	Volume / Section / Clause No.	Page No.	Clause Description	Bidder's Query	Reply to Bidder's Query
1)	Section 1.1 & 1.1.3 (PART-I)	13	Bid Evaluation Criteria	<p>The bidder must have supplied the quantity as indicated for each type of Natural Gas Regulators under a single order in last seven years reckoned from the bid due date.</p> <p>Please amend the Criteria to incorporate as follows If bidder has quoted as an authorized dealer / distributor, then corresponding manufacturer's experience and facility will be considered for qualification.</p>	<p>There will be no change in the Bid Evaluation Criteria (BEC).</p> <p>Tender conditions prevail.</p>
2)	Section 1.2 & 16.9 (PART-I)	35	EARNEST MONEY DEPOSIT/ BID SECURITY	<p>EARNEST MONEY DEPOSIT (EMD) MSEs (Micro & Small Enterprise) are exempted from submission of EMD / Bid Security in accordance with provisions of PPP-2012 as stipulated in clause 39 of ITB. However, Traders / Dealers / Distributors / stockiest / Wholesaler registered with DIC are not entitled for exemption of EMD. The Government Department / PSUs are also exempted from the payment of Bid Security.</p> <p>We are qualified as a Trader, Distributor & Wholesaler in Micro & Small Enterprise. According to Government of India regulations, all the companies which are registered as Micro, Small under MSME or registered as N.S.I.C shall be exempted from submission of EMD. For your reference the MSME Certificate is enclosed.</p>	<p>Exemptions with regard to the PUBLIC PROCUREMENT POLICY FOR MICRO AND SMALL ENTERPRISES will be as per clause no. 39 of ITB (Pg.48).</p> <p>The benefit of policy are not extended to the traders/ dealers/ Distributors/ Stockiest/ Wholesalers (refer cl. no. 39.5)</p>

Sr. No.	Volume / Section / Clause No.	Page No.	Clause Description	Bidder's Query	Reply to Bidder's Query
3)	Technical Specification & Data Sheets (PART-III)	-	DOMESTIC REGULATORS (GROUP-A)	A.2 – 2.5M3/Hr Capacity Natural Gas Regulator with OPSO, UPSO and Creep Relief Valve - Regarding the DESIGN of the regulator, in the specification sheet of the tender document you have requested for the Regulators with built in Two Stage Regulation. We have been supplying similar Regulator with Single Stage Regulation to various CGD companies in the Country for over two decades now. Proven and trouble free performance in the field has supported them taking the decision to continue with this single stage regulator for all these years. Hence we request you to kindly also accept the single stage regulator for your requirements.	The regulators shall be as per Technical Specification (TS) of the Tender document. Tender clause prevail.
4)	Technical Specification & Data Sheets (PART-III)	-	DOMESTIC REGULATORS (GROUP-A)	A.3 - 6.5M3/Hr Capacity Natural Gas Regulator with OPSO, UPSO and Creep Relief Valve - Regarding the DESIGN of the regulator, in the specification sheet of the tender document you have requested for the Regulators with built in Two Stage Regulation. We have been supplying similar Regulator with Single Stage Regulation to various CGD Companies in the country. Hence we request you to kindly also accept the Single Stage Regulator for your requirements.	The regulators shall be as per Technical Specification (TS) of the Tender document. Tender clause prevail.
5)	Technical Specification & Data Sheets (PART-III)	-	SERVICE REGULATORS (GROUP-B)	B.1 – 10 SCMH Capacity Natural Gas Service Regulator with OPSO, UPSO and Creep Relief Valve - Regarding the DESIGN of the regulator, in the specification sheet of the tender document you have requested for the Regulators with built in Two Stage Regulation. We have been supplying similar Regulator with Single Stage Regulation to various CGD Companies in the country. Hence we	The regulators shall be as per Technical Specification (TS) of the Tender document. Tender clause prevail.

Sr. No.	Volume / Section / Clause No.	Page No.	Clause Description	Bidder's Query	Reply to Bidder's Query
				request you to kindly also accept the Single Stage Regulator for your requirements.	

Note: This document shall form an integral part of the bidding document and shall be signed/stamped and submitted along with the bid.

(STAMP & SIGNATURE OF BIDDER)