



A Joint Venture of Andhra Pradesh Gas Distribution Corporation Ltd. and
Hindustan Petroleum Corporation Ltd

CORRIGENDUM – 6

Date: 28.03.2019

Tender Document No: GGPL/KKD/C&P/PR 2034/2018-19/26 dated 06.03.2019

Subject: Tender for Supply of CNG Storage Stationary and Mobile Cascades for DBS(s) and Mother Stations of GGPL in East & West Godavari Districts

The following modifications to the subject tender is hereby authorized

S. No.	Description	Page No. / Clause No.	Amendment/Addition/ Modification
1	REPLIES TO BIDDERS QUERIES	-	As per Annexure-I of this document

All other terms and conditions of tender document remain unchanged

Authorized Signatory

ANNEXURE-I

Tender No. : GGPL/KKD/C&P/PR 2034/20118-19/26				REPLIES TO BIDDERS QUERIES		
S. No	Clause No.	Page	GGPL Previous Reply	Deviation	Clarification	GGPL Reply
1	Corr. 2, Sr. No. 1 & Corr. 2, Sr. No. 2	1	DUE DATE AND TIME OF BID- SUBMISSION: 27.03.2019 at 14:00 Hrs. (1ST)	15-Apr-2019 at 14:00 Hrs. (1ST)		DUE DATE AND TIME OF BID- SUBMISSION: extended till 04.04.2019 at 14:00 Hrs.(1ST) vide Corrigendum-5
2	Corr. 3, Annex-I, Sr. No. 7	4	Clause remain Unchanged	Bidder will submit calculation sheet only, No Test results and/or reports for 4G	Please refer Sr. No. 4, CORRIGENDUM No. 4 to Tender Document No: GGPUC&P/Pur/4717/2016 - 17 Date: 18/02/2017 where you agreed this deviation. Request you to now also, please accept.	refer corrigendum-4 dated 25.03.2019
3	Corr. 3, Annex-I, Sr. No. 8	4	Clause remain Unchanged	Canopy size shall be equal to length and width of cascade, no extension of 1 foot.	Please refer Sr. No.5, CORRIGENDUM No. 4 to Tender Document No: GGPUC&P/Pur/4717/2016 - 17 Date: 18/02/2017 where you agreed this deviation. Request you to now also, please accept.	unchanged, it is as per the observation and recommendation of local PESO authority

4	Corr. 3, Annex-I, Sr. No. 11	5	Unchanged	All end connections, pressure gauges, valves and fittings of cascade shall be within tamper proof, wire cage enclosure or acrylic sheet header box constructed with structural steel.	Proposing to add acrylic sheet header box constructed with structural steel having advantage of transparency for gauge visibility. Please refer enclosed photographs showing: 1. ACRYLIC SHEET HEADER BOX, and 2. WIRE CAGE ENCLOSURE	Agreed
5	Corr. 3, Annex-I, Sr. No. 24	8	Delivery schedule clause remains unchanged	Delivery schedule-12 weeks from the receipt of Purchase Order and Approved Drawing whichever is later	1. Actual Manufacturing process will start, after the receipt of Approved Drawing from Customer only 2. LD clause counting shall be start from date of drawing approval and not from date of LOI	Unchanged

1. ACRYLIC SHEET HEADER BOX



2. WIRE CAGE ENCLOSURE

